

August 06, 2012

STATEMENT OF COMPLIANCE

Product: 12V PS and PG Series Batteries

The batteries referenced above are suitable for use in fire booster pump installations.

These batteries are of the type: "Standby Sealed Lead Acid" battery and comply to the standard A4029.2:2000.

Because they comply to AS4029.2, they in turn also comply to the items relevant to battery in standard AS2941 in particular items 3.13.6, and 9.3.6.3.

The actual capacity and cranking requirements of clause 9.3.6.2. is determined by the customer depending on the application.

Note: The standards referenced above do not require the battery to have flame retardant cases.

Sincerely

POWER-SONIC CORPORATION



Bruno Ender
Director of International Sales